



INSTALLATION NOTES

1. With shield rotated to open position (approximately 90° to cover), insert shield pivots into slots on Stopper Station cover.
2. Rotate cover to closed position.
Rotate cover to fully open position, back to closed position, and ensure the button level is pressed down onto the button. If not, repeat steps 2-5. Program the sounder volume on or off by pulling off the plastic battery tab with the battery remaining installed. (Sounder will be on at this point.) The sounder volume programming cycle is ON for 10 seconds, OFF for 10 seconds, and then defaults to ON. To set volume: open the Shield, close, open again and close again.
3. Mount shield and cover onto Stopper Station button assembly.
4. Install screw to hold cover to button assembly.

⚠ WARNING: This product can expose you to chemicals including Dichloromethane, which is known to the State of California to cause cancer, and Bisphenol A (BPA), which is known to the State of California to cause birth defects or other reproductive harm. For more information go to www.P65Warnings.ca.gov.

Three year warranty or a one year limited warranty (from date of purchase) on most products. See website for details. Electronic warranty form at www.sti-usa.com/wc14.

INSTALLATION OF STI-6517 STI STOPPER® STATION SHIELD

All specifications and information shown were current as of publication and are subject to change without notice.

6517IS MARCH2010

